

**COLUMBUS METROPOLITAN HOUSING AUTHORITY**

**880 East 11th Avenue**

**COLUMBUS, OHIO 43211**

**DATE: December 6, 2023**

**RFP# 2023-026**

**TO ALL BIDDERS:**

**The specifications are hereby amended and supplemented by this addendum, which will form a part of the contract documents and should be considered in preparation of bid.**

**ADDENDUM # 1**

1. Cut off for question for this RFP Service Request?
  - a. Wednesday, December 6, 2023 @ 4:30pm
2. Have you ever installed Cameras at this site before?
  - a. Yes,
  - b. 2014
3. How many cameras did you have installed at this site during the previous camera installation?
  - a. Previous specification Installation of one (1) General Surveillance CCTV Package consisting of twelve (12) subscriber stations, one (1) wireless base station, thirteen (13) industrial switches, one (1) Pelco\* NVR, five (5) Pelco\* 360· degree cameras, eleven (11) Pelco\* 2 megapixel dome cameras, one (1) PoE port switch, one (1) wall rack with keyboard tray and one (1) LCD 21" monitor. All new cameras and NVR will be Pelco\* equipment with the following features included: One (1) – Pelco\* DSSRV-180-US Network Video Recorder with rack mounts, keyboard and mouse. Five (5) – Pelco\* 5-MP Evolution 360· Outdoor Dome, IP66-Rated, Client-Side Dewarping, WDR, Low-Light Cameras, Eleven (11) – Pelco\* IP66 Rated IP Mini Domes with up to 2 MPX, H.264, WDR, LowLight Performance, Anti-Bloom, and Auto-Focus - Sarix IME Series Environmental Mini Domes with SureVision, One (1) Utility Pole. Recommended 3 MB minimum 1.5 MB per Location for Optimum Transmission Speed to View Station Monitoring.
4. Are the cameras still installed and in use at this site?
  - a. Some of the cameras are still installed at the site, they are not operable.
5. Was CMHA happy with the location of the camera installation at the Sawyer/Trevitt previously.
  - a. Yes
6. How much coverage is required for the site?
  - a. The entire property.
  - b. CMHA is expecting suggestions from the proposer.
7. Can we submit cost and coverage for cameras and security site visits?
  - a. CMHA is not looking for security site visits.
  - b. If you submit this service and cost, ensure you list it as an additional option available.

8. According to your scope of work, you reference "LiveView" as a specification, is that a typo or an intended phrase?
  - a. CMHA is seeking real time camera views.
  - b. CMHA is not targeting to purchase "LiveView" brand equipment.
9. Does CMHA want to own this equipment?
  - a. No CMHA does not want to be responsible for maintenance, repairs or service for the video surveillance service.
  - b. The awardee will be responsible for repairs & maintenance.
10. Would CMHA accept Verkada Cameras if they meet all the specifications in your RFP?
  - a. CMHA has not identified an brand requirement for this service.
11. What type of wifi connection is available at the site for this service?
  - a. None
  - b. Proposer is responsible for all wifi connections
12. Will proposer be required to provide the wifi connection or will CMHA provide the connection?
  - a. Yes